

MIKE NOVO
ZONING ADMINISTRATOR

COUNTY OF MONTEREY
STATE OF CALIFORNIA

RESOLUTION NO. 040497

A. P. # 417-032-015-000

In the matter of the application of
Russell Murray (Pospishil) (PLN040497)

FINDINGS & DECISION

to allow a Combined Development Permit in accordance with Title 21 (Zoning) Chapter 21.76 (Combined Development Permits) of the Monterey County Code, consisting of an Administrative Permit for construction of a new 2,986 sq. ft. single family dwelling, a 12,623 gallon lap pool, a 421 sq. ft. office atop a barn and two single-car carports in a site plan review district and Design Approval; and a Use Permit for removal of four oak trees and a Use Permit for development on slopes in excess of 30 percent. The property is located at 108 Hitchcock Road, Carmel Valley, approximately one mile south of the end of Southbank Road, southeast of Carmel Valley Village, Carmel Valley Master Plan area. The project came on regularly for meeting before the Zoning Administrator on February 24, 2005.

Said Zoning Administrator, having considered the application and the evidence presented relating thereto,

- 1. FINDING:** The proposed project (PLN040497) as described in Condition No. 1 and as conditioned conforms with the plans, policies, requirements and standards of the General Plan, Carmel Valley Master Plan and Monterey County Zoning Ordinance (Title 21). The property is located at 108 Hitchcock Canyon, Road, Carmel Valley (Assessor's Parcel Number 417-032-015-000). The parcel is zoned Low Density Residential/2.5 Design Approval/Building Site Residential Allocation Zoning District (LDR/2.5-D-S-RAZ). The land use entitlements conferred by this permit shall not commence unless and until all of the conditions of this permit are met to the satisfaction of the Director of Planning and Building Inspection.

EVIDENCE: The application and plans submitted for the project contained in project file PLN040497 at the Monterey County Planning and Building Inspection Department. Staff has reviewed this material and has determined that the project is consistent with the Monterey County General Plan, the Carmel Valley Area Master Plan and Title 21 of the County Zoning Code.

EVIDENCE: Recommendation for approval (4-0) from the Carmel Valley Land Use Advisory Committee from its September 6, 2004 meeting.

EVIDENCE: There has been no testimony received either written or oral, during the course of public hearings to indicate that the site is not suitable for the project. Necessary public facilities are available for the use proposed. The project has been reviewed by the Monterey County Planning and Building Inspection Department, Water Resources Agency, the Carmel Valley Fire Protection District, Public Works Department and Environmental Health Division. There has been no indication from those agencies that the site is not suitable. There are no physical or environmental constraints such as geologic or seismic hazard areas, environmentally sensitive habitats, or similar areas that would indicate the site is not suitable for the use proposed.

2. **FINDING:** The approved project will not have a significant adverse impact on the environment.
EVIDENCE: Section 15303 of the California Environmental Quality Act Guidelines (New Construction or Conversion of Small Structures) categorically exempts this project from environmental review.
EVIDENCE: Project plans and materials in project file PLN040497.
3. **FINDING:** The establishment, maintenance, or operation of the use or building applied for will not under the circumstances of the particular case, be detrimental to the health, safety, peace, morals, comfort, and general welfare of persons residing or working in the neighborhood or to the general welfare of the County.
EVIDENCE: The project as described in the application and accompanying materials was reviewed by the Planning and Building Inspection Department, Environmental Health Department, the Public Works Department, the Carmel Valley Fire District, and the Water Resources Agency. The respective departments have recommended conditions, where appropriate, to ensure that the project will not have an adverse effect on the health, safety, and welfare of persons either residing or working in the neighborhood; or the county in general.
EVIDENCE: Project plans and application materials in project file PLN040497
EVIDENCE: There has been no testimony received either written or oral, during the course of public hearings to indicate that the site is not suitable for the project. Necessary public facilities are available for the use proposed. The project has been reviewed by the Monterey County Planning and Building Inspection Department, Water Resources Agency, the Carmel Valley Rural Fire District, Public Works Department and Environmental Health Division. There has been no indication from those agencies that the site is not suitable. There are no physical or environmental constraints such as geologic or seismic hazard areas, environmentally sensitive habitats, or similar areas that would indicate the site is not suitable for the use proposed.
EVIDENCE: The Carmel Valley Land Use Advisory Committee voted to recommend approval (4-0) of the project on September 6, 2004.
4. **FINDING:** The subject site is in compliance with all rules and regulations pertaining to zoning uses, subdivision, and any other applicable provisions of Title 21 and any zoning abatement costs have been paid.
EVIDENCE: Staff reviewed Monterey County Planning and Building Inspection Department records and is not aware of any violations existing on subject property.
5. **FINDING:** The tree removal is the minimum required under the circumstances of the case and will not involve a risk of adverse environmental impacts such as soil erosion, water quality, ecological impacts, noise pollution, air movement, and wildlife habitat.
EVIDENCE: A site visit by the project planner.
EVIDENCE: Evidence for Finding 1.

DECISION

It is the decision of the Zoning Administrator of the County of Monterey that said application for a Combined Development Permit be granted as shown on the attached sketch and subject to the following conditions:

PASSED AND ADOPTED this 24th day of February, 2005.

MIKE NOVO
ZONING ADMINISTRATOR

COPY OF THIS DECISION MAILED TO APPLICANT ON

IF ANYONE WISHES TO APPEAL THIS DECISION, AN APPEAL FORM MUST BE COMPLETED AND SUBMITTED TO THE SECRETARY TO THE PLANNING COMMISSION ALONG WITH THE APPROPRIATE FILING FEE ON OR BEFORE

This decision, if this is the final administrative decision, is subject to judicial review pursuant to California Code of Civil Procedure Sections 1094.5 and 1094.6. Any Petition for Writ of Mandate must be filed with the Court no later than the 90th day following the date on which this decision becomes final.

NOTES

1. You will need a building permit and must comply with the Monterey County Building Ordinance in every respect.

Additionally, the Zoning Ordinance provides that no building permit shall be issued, nor any use conducted, otherwise than in accordance with the conditions and terms of the permit granted or until ten days after the mailing of notice of the granting of the permit by the appropriate authority, or after granting of the permit by the Board of Supervisors in the event of appeal.

Do not start any construction or occupy any building until you have obtained the necessary permits and use clearances from the Monterey County Planning and Building Inspection Department office in Marina.

2. This permit expires 2 years after the above date of granting thereof unless construction or use is started within this period.

Monterey County Planning and Building Inspection
Condition Compliance and/or Mitigation Monitoring Reporting Plan

Project Name: *Pospishil*

File No: PLN040497 APNs: 417-032-015-000

Approval by: Zoning Administrator Date: February 24, 2005

**Monitoring or Reporting refers to projects with an EIR or adopted Mitigated Negative Declaration per Section 21081.6 of the Public Resources Code.*

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
1		<p>PBD029 - SPECIFIC USES ONLY</p> <p>This combined development permit (PLN040407) allows construction of a new 2,986 sq. ft. single family dwelling, a 12,623 gallon lap pool, a 1,368 sq. ft. horse barn with a 421 sq. ft. office on the second level and two single-bay carports, the removal of four Oak trees, development on slopes in excess of 30 percent, and approximately 200 cu. yds. of grading (no export). The property is located at 108 Hitchcock Canyon Road, (Assessor's Parcel Number 417-032-015-000). This permit was approved in accordance with County ordinances and land use regulations subject to the following terms and conditions. Neither the uses nor the construction allowed by this permit shall commence unless and until all of the conditions of this permit are met to the satisfaction of the Director of Planning and Building Inspection. Any use or construction not in substantial conformance with the terms and conditions of this permit is a violation of County regulations and may result in modification or revocation of this permit and subsequent legal action. No use or construction other than that specified by this permit is allowed unless additional permits are approved by the appropriate authorities. (Planning and Building Inspection)</p>	Adhere to conditions and uses specified in the permit.	Owner/ Applicant	Ongoing unless other- wise stated	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
2		PBD025 - NOTICE-PERMIT APPROVAL The applicant shall record a notice which states: "A permit (Resolution 040497) was approved by the Zoning Administrator for Assessor's Parcel Number 417-032-015-000 on February 24, 2005. The permit was granted subject to 20 conditions of approval which run with the land. A copy of the permit is on file with the Monterey County Planning and Building Inspection Department." Proof of recordation of this notice shall be furnished to the Director of Planning and Building Inspection prior to issuance of building permits or commencement of the use. (Planning and Building Inspection)	Proof of recordation of this notice shall be furnished to PBI.	Owner/ Applicant	Prior to Issuance of grading and building permits or start of use.	
3		PBD030 - STOP WORK - RESOURCES FOUND If, during the course of construction, cultural, archaeological, historical or paleontological resources are uncovered at the site (surface or subsurface resources) work shall be halted immediately within 50 meters (165 feet) of the find until a qualified professional archaeologist can evaluate it. The Monterey County Planning and Building Inspection Department and a qualified archaeologist (i.e., an archaeologist registered with the Society of Professional Archaeologists) shall be immediately contacted by the responsible individual present on-site. When contacted, the project planner and the archaeologist shall immediately visit the site to determine the extent of the resources and to develop proper mitigation measures required for the discovery. (Planning and Building Inspection)	Stop work within 50 meters (165 feet) of uncovered resource and contact the Monterey County Planning and Building Inspection Department and a qualified archaeologist immediately if cultural, archaeological, historical or paleontological resources are uncovered. When contacted, the project planner and the archaeologist shall immediately visit the site to determine the extent of the resources and to develop proper mitigation measures required for the discovery.	Owner/ Applicant/ Archaeologist	Ongoing	
4		Only opaque or shaded skylights shall be permitted and all exterior lighting shall be down lit to prevent off-site intrusion. (Planning and Building Inspection).				
5		Neither carport shall exceed 15' in height. (measured as an average between the lowest and highest points from natural grade). Planning and Building Inspection				

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
6		PBD (NON STANDARD) The four oak trees to be removed shall be replaced on a 1:1 ratio on site. The minimum size of replacement trees shall be 5 gallon. Replacement trees shall be positioned no closer than 10 feet to each other. Prior to issuance of grading and building permits, the applicant shall submit a plan to the Planning and Building Inspection Director that identifies the location of the replacement trees. The applicant shall also submit a short and long term maintenance plan to ensure survivability of the replacement trees. (Planning and Building Inspection)	Submit plan to Planning and Building Inspection Department.	Owner/ Applicant	Prior to issuance of a Building Permit	
7		PW0006 – CARMEL VALLEY The Applicant shall pay the Carmel Valley Master Plan Area Traffic Mitigation fee pursuant to the Board of Supervisors Resolution NO. 95-140, adopted September 12, 1995 (Fees are updated annually based on CCI). (Public Works)	Applicant shall pay to PBI the required traffic mitigation fee.	Owner/ Applicant	Prior to Building Permits Issuance	
8		SEPTIC SYSTEM Installation of septic system shall conform to design by Soil Surveys, Inc. Approved plans dated December 1, 2004. (Environmental Health)	Applicant	Owner /Applicant	Ongoing	
9		WR3 - DRAINAGE PLAN - RETENTION The applicant shall provide the Water Resources Agency a drainage plan prepared by a registered civil engineer or architect addressing on-site and off-site impacts. The plan shall include retention/percolation facilities to mitigate the impact of impervious surface stormwater runoff. Drainage improvements shall be constructed in accordance with plans approved by the Water Resources Agency. (Water Resources Agency)	Submit 3 copies of the engineered drainage plan to the Water Resources Agency for review and approval.	Owner/ Applicant/ engineer	Prior to issuance of grading or building permits	
10		WR43 - WATER AVAILABILITY CERTIFICATION The applicant shall obtain from the Monterey County Water Resources Agency, proof of water availability on the property, in the form of an approved Monterey Peninsula Water Management District Water Release Form. (Water Resources Agency)	Submit the Water Release Form to the Water Resources Agency for review and approval.	Owner/ Applicant	Prior to issuance of any building permits	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
11		WR45 - WELL INFORMATION The applicant shall provide the Water Resources Agency information on the well to serve the project including a map showing the well location and any available well logs/e-logs. (Water Resources Agency)	Submit all applicable well information to the Water Resources Agency for review and approval.	Owner/ Applicant	Prior to issuance of any grading or building permits	
12	2	WR8 - COMPLETION CERTIFICATION The applicant shall provide the Water Resources Agency certification from a registered civil engineer or licensed contractor that stormwater detention/retention facilities have been constructed in accordance with approved plans. (Water Resources Agency)	Submit a letter to the Water Resources Agency, prepared by a registered civil engineer or licensed contractor, certifying compliance with approved drainage plan.	Owner/ Applicant/ Engineer/ Contractor	Prior to final inspection	
13		WR40 - WATER CONSERVATION MEASURES The applicant shall comply with Ordinance No. 3932, or as subsequently amended, of the Monterey County Water Resources Agency pertaining to mandatory water conservation regulations. The regulations for new construction require, but are not limited to: a. All toilets shall be ultra-low flush toilets with a maximum tank size or flush capacity of 1.6 gallons, all shower heads shall have a maximum flow capacity of 2.5 gallons per minute, and all hot water faucets that have more than ten feet of pipe between the faucet and the hot water heater serving such faucet shall be equipped with a hot water recirculating system. b. Landscape plans shall apply xeriscape principles, including such techniques and materials as native or low water use plants and low precipitation sprinkler heads, bubblers, drip irrigation systems and timing devices. (Water Resources Agency)	Compliance to be verified by building inspector at final inspection.	Owner/ Applicant	Prior to final building inspection/occupancy	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
14		<p><u>FIRE007 - DRIVEWAYS</u> Driveways shall not be less than 12 feet wide unobstructed, with an unobstructed vertical clearance of not less than 15 feet. The grade for all driveways shall not exceed 15 percent. Where the grade exceeds 8 percent, a minimum structural roadway surface of 0.17 feet of asphaltic concrete on 0.34 feet of aggregate base shall be required. The driveway surface shall be capable of supporting the imposed load of fire apparatus (22 tons), and be accessible by conventional-drive vehicles, including sedans. For driveways with turns 90 degrees and less, the minimum horizontal inside radius of curvature shall be 25 feet. For driveways with turns greater than 90 degrees, the minimum horizontal inside radius curvature shall be 28 feet. For all driveway turns, an additional surface of 4 feet shall be added. All driveways exceeding 150 feet in length, but less than 800 feet in length, shall provide a turnout near the midpoint of the driveway. Where the driveway exceeds 800 feet, turnouts shall be provided at no greater than 400-foot intervals. Turnouts shall be a minimum of 12 feet wide and 30 feet long with a minimum of 25-foot taper at both ends. Turnarounds shall be required on driveways in excess of 150 feet of surface length and shall long with a minimum 25-foot taper at both ends. Turnarounds shall be required on driveways in excess of 150 feet of surface length and shall be located within 50 feet of the primary building. The minimum turning radius for a turnaround shall be 40 feet from the center line of the driveway. If a hammerhead/T is used, the top of the "T" shall be a minimum of 60 feet in length. (Carmel Valley Fire Protection District)</p>	Applicant shall incorporate specification into design and enumerate as "Fire Dept. Notes" on plans.	Applicant or owner	Prior to issuance of grading and/or building permit.	
			Applicant shall schedule fire dept. clearance inspection	Applicant or owner	Prior to final building inspection.	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
15		<p>FIRE011 - ADDRESSES FOR BUILDINGS</p> <p>All buildings shall be issued an address in accordance with Monterey County Ordinance No. 1241. Each occupancy, except accessory buildings, shall have its own permanently posted address. When multiple occupancies exist within a single building, each individual occupancy shall be separately identified by its own address. Letters, numbers and symbols for addresses shall be a minimum of 4-inch height, 1/2-inch stroke, contrasting with the background color of the sign, and shall be Arabic. The sign and numbers shall be reflective and made of a noncombustible material. Address signs shall be placed at each driveway entrance and at each driveway split. Address signs shall be and visible from both directions of travel along the road. In all cases, the address shall be posted at the beginning of construction and shall be maintained thereafter. Address signs along one-way roads shall be visible from both directions of travel. Where multiple addresses are required at a single driveway, they shall be mounted on a single sign. Where a roadway provides access solely to a single commercial occupancy, the address sign shall be placed at the nearest road intersection providing access to that site. Permanent address numbers shall be posted prior to requesting final clearance. (Carmel Valley Fire Protection District)</p>	Applicant shall incorporate specification into design and enumerate as “Fire Dept. Notes” on plans.	Applicant or owner	Prior to issuance of building permit.	
			Applicant shall schedule fire dept. clearance inspection	Applicant or owner	Prior to final building inspection	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
16		<p>FIRE015 - FIRE HYDRANTS/FIRE VALVES</p> <p>A fire hydrant or fire valve is required. The hydrant or fire valve shall be 18 inches above grade, 8 feet from flammable vegetation, no closer than 4 feet nor further than 12 feet from a roadway, and in a location where fire apparatus using it will not block the roadway. The hydrant serving any building shall be not less than 50 feet and not more than 1000 feet by road from the building it is to serve. Minimum hydrant standards shall include a brass head and valve with at least one 2 1/2 inch National Hose outlet supplied by a minimum 4 inch main and riser. More restrictive hydrant requirements may be applied by the Reviewing Authority. Each hydrant/valve shall be identified with a reflectorized blue marker, with minimum dimensions of 3 inches, located on the driveway address sign, non-combustible post or fire hydrant riser. If used, the post shall be within 3 feet of the hydrant/valve, with the blue marker not less than 3 feet or greater than 5 feet above the ground, visible from the driveway. On paved roads or driveways, reflectorized blue markers shall be permitted to be installed in accordance with the State Fire Marshal's Guidelines for Fire Hydrant Markings Along State Highways and Freeways, May 1988. (Carmel Valley Fire Protection District)</p>	Applicant shall incorporate specification into design and enumerate as "Fire Dept. Notes" on plans.	Applicant or owner	Prior to issuance of grading and/or building permit.	
			Applicant shall schedule fire dept. clearance inspection	Applicant or owner	Prior to final building inspection	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
17		<u>FIRE019 - DEFENSIBLE SPACE REQUIREMENTS - (STANDARD)</u> Remove combustible vegetation from within a minimum of 30 feet of structures. Limb trees 6 feet up from ground. Remove limbs within 10 feet of chimneys. Additional and/or alternate fire protection or firebreaks approved by the fire authority may be required to provide reasonable fire safety. Environmentally sensitive areas may require alternative fire protection, to be determined by Reviewing Authority and the Director of Planning and Building Inspection. (Carmel Valley Fire Protection District).	Applicant shall incorporate specification into design and enumerate as “Fire Dept. Notes” on plans.	Applicant or owner	Prior to issuance of grading and/or building permit.	
			Applicant shall schedule fire dept. clearance inspection	Applicant or owner	Prior to final building inspection	
18		<u>FIRE021 - FIRE PROTECTION EQUIPMENT & SYSTEMS - FIRE SPRINKLER SYSTEM (STANDARD)</u> The building(s) and attached garage(s) shall be fully protected with automatic fire sprinkler system(s). Installation shall be in accordance with the applicable NFPA standard. A minimum of four (4) sets of plans for fire sprinkler systems must be submitted by a California licensed C-16 contractor and approved prior to installation. This requirement is not intended to delay issuance of a building permit. A rough sprinkler inspection must be scheduled by the installing contractor and completed prior to requesting a framing inspection. (Carmel Valley Fire Protection District)	Applicant shall enumerate as “Fire Dept. Notes” on plans.	Applicant or owner	Prior to issuance of building permit.	
			Applicant shall schedule fire dept. rough sprinkler inspection	Applicant or owner	Prior to framing inspection	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
			Applicant shall schedule fire dept. final sprinkler inspection	Applicant or owner	Prior to final building inspection	
19		<u>FIRE014 - EMERGENCY WATER STANDARDS - FIRE PROTECTION WATER SUPPLY - (SINGLE PARCEL)</u> For development of structures totaling less than 3,000 square feet on a single parcel, the minimum fire protection water supply shall be 4,900 gallons. For development of structures totaling 3,000 square feet or more on a single parcel, the minimum fire protection water supply shall be 9,800 gallons. For development of structures totaling more than 10,000 square feet on a single parcel, the reviewing authority may require additional fire protection water supply. Other water supply alternatives, including ISO Rural Class 8 mobile water systems, may be permitted by the fire authority to provide for the same practical effect. The quantity of water required by this condition shall be in addition to the domestic demand and shall be permanently and immediately available. (Carmel Valley Fire Protection District)	Applicant shall incorporate specification into design and enumerate as “Fire Dept. Notes” on plans.	Applicant or owner	Prior to issuance of grading and/or building permit.	
			Applicant shall schedule fire dept. clearance inspection	Applicant or owner	Prior to final building inspection	
20		<u>FIRE028 - ROOF CONSTRUCTION - (CARMEL VALLEY FPD)</u> All new structures, and all existing structures receiving new roofing over 50 percent or more of the existing roof surface within a one-year period, shall require a minimum of ICBO Class A roof construction. (Carmel Valley Fire Protection District)	Applicant shall enumerate as “Fire Dept. Notes” on plans.	Applicant or owner	Prior to issuance of building permit.	

<i>Permit Cond. Number</i>	<i>Mitig. Number</i>	<i>Conditions of Approval and/or Mitigation Measures and Responsible Land Use Department</i>	<i>Compliance or Monitoring Actions to be performed. Where applicable, a certified professional is required for action to be accepted.</i>	<i>Responsible Party for Compliance</i>	<i>Timing</i>	<i>Verification of Compliance (name/date)</i>
		End of Conditions				